

**MUNICIPAL COPORATION OF DELHI**  
**PUBLIC HEALTH DEPARTMENT**  
**SHAHDARA NORTH ZONE**

No.DHO/Shah(N)/2024(D-64

Dated 29/04/24

**SCHOOL INSPECTION REPORT**

In reference to your application duly submitted in the office of undersigned vide diary no. 97 dated 15.04.2024. the inspection of " St. Marks Sr. Sec. Public School" at Lal Mandir Road, Harsh Vihar, Delhi-110093 was carried out on dated 15.04.2024. During the inspection. It was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.



**Dy. Health Officer**

**Shahdara North Zone**  
श्री अजय कुमार  
उप स्वास्थ्य अधिकारी  
शाहदारा उत्तरी क्षेत्र

**H.O.S**  
**ST. MARKS SR. SEC. PUBLIC SCHOOL**  
**LAL MANDIR ROAD**  
**HARSH VIHAR, DELHI-110093**

ACWA TYR  
Query No. 542 dt 9/9/2020

**DELHI JAL BOARD**  
(GOVT. OF NCT DELHI)  
**QUALITY CONTROL ZONAL LABORATORY**  
**TRANS YAMUNA REGION TAHIRPUR DELHI-93.**

NO: DJB/ACWA(TYR)/2020.....

DATE: 04-09-2020

Analysis report of D.J.B. supply samples collected from (1) Inlet (2) Outlet for drinking purpose at ST. Marks St. Sec. Public School, Lal Mandir Road, Harsh Vihar, Delhi-93. M/S Principal.  
Ref No.- SMPS/2020/1212 dated-24.08.2020 .

Date of collection:-29-08-2020

Challan no-111

dated: 25-08-2020

S. No.	PARTICULARS	LIMITS	UNIT	RESULT	
				(1)	(2)
A.	<b>Physical Examination</b>				
1.	Colour	...		Clear	Clear
2.	Odour	...		Chlo.	Chlo.
3.	Turbidity	(1-5)	NTU	0.92	1.10
4.	pH Value	(6.5 to 8.5)		7.6	7.6
5.	Electrical Conductivity	--	ms/cm	310	351
6.	Total Dissolved Solids	(500-2000)	mg/l	201	228
B.	<b>Chemical Examination</b>				
1.	p <sup>h</sup> Alkalinity	--	mg/l	Nil	Nil
2.	Total Alkalinity	(200-600)	"	64	74
3.	Free Carbondioxide	--	"	4	4
4.	Total Hardness	(200-600)	"	104	122
5.	Ca Hardness	--	"	64	80
6.	Mg Hardness	--	"	40	42
7.	Calcium as (Ca)	(75-200)	"	25.6	32
8.	Magnesium as (Mg)	(30-100)	"	9.6	10.08
9.	Ammonia	(0.5)	"	N.D	N.D
10.	Nitrite	--	"	N.D	N.D
11.	Nitrate	45	"	4.72	6.48
12.	Sulphate	(200-400)	"	29.6	41.4
13.	Chloride	(200-1000)	"	32	34
14.	Fluoride	(1.0-1.5)	"	0.37	0.38
15.	Total Iron	(0.3)	"	0.08	0.08
16.	Residual Chlorine	(0.2-1.0)	"	1.00	Tr.
C.	<b>Bacteriological Examination</b>				
17.	Coliform count		MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS: (1) On the basis of tested parameters, both water samples confirm BIS: 10500-2012 and can be consider fit for drinking purpose.

*J. Deshpande*  
A/CHEMIST

*[Signature]*

**Manager**  
St Marks, Sr. Sec. Public School  
Harsh Vihar, Delhi-110093

*K. Singh*  
CHEMIST

*S. Singh*  
Principal  
St. Marks Sr. Sec. Public School

*K. Singh*  
ACWA (TYR) 4/9/2020

Asstt. Chief Water Analyst  
D.J.B. Govt. of N.C.T. of Delhi  
Quality Control Zonal Laboratory (TYR)  
Tahir Pur Dilshad Cantonment, Delhi-110043